



Image for demonstration purposes

## **Generating Set Base Frame - diesel**

# GE.CU.055/050.BF+011

1500 rpm - Threephase - 50Hz - 400V Automatic Panel with AMF without ATS



# **Standard equipment**

# Exhaust

Exhaust manifold protection Silenced muffler -15dB(A)

## Fuel Supply

Single wall daily tank with bunded base Automatic shutdown system for low fuel level Fuel gauge

### **Handling**

Base frame with anti-overturning forklift pockets Forkliftable on the short side

## Base Frame

Bunded base at 110% of fuel tank capacity Anti-vibrating mounting pads

# Engine

High coolant temperature and low oil pressure shutdown External oil drain points Engine liquids (oil and antifreeze) Tropicalized radiator Rotating parts protection

## Alternator

Avr automatic voltage regulator Impregnation for marine environment lp23

## Panel & connection

Emergency stop button Magnetothermal circuit breaker on alternator board Cable output from side lp44 wiring Start-up battery (pre-charged) Grounding point

#### Documentation

Ce conformity declaration User and maintenance manual Wirings diagrams

# Normatives •

All generating sets are compliant to CE marking 2014/30/UE electromagnetic compatibility 2000/14/CE noise emission for outdoor use Factory-designed systems built according to ISO 9001:2015 CEI EN 60204-1:2018 - Electrical equipment of machines















# **Primary data**

Exhaust gas flow

Exhaust diameter

Combustion air flow

Dimensions (l x w x h)

Weight and Dimensions

Weight with liquids (excluding optionals and fuel)

Speed	RPM	1500
Frequency	Hz	50
PRP	KVA	50
Prp - prime power	KW	40,0
Ltp - standby power	KVA	55
Ltp - standby power	KW	44,0
Standard voltage	V	400/230
Current	Α	72,3
Cosfi	0,8	0,8
General electrical protection  Circuit-breaker rated current	А	80
Circuit-breaker rated current	Α	80
Type		Magnetothermal switch on the alternator board
Circuit-breaker poles	N	4P
Fuel Consumption		
Туре		diesel
Standard fuel tank capacity	lt	110
Autonomy @ 75% load	h	12
Fuel consumption at 100% load	lt/h	12,8
Fuel consumption at 75% load	lt/h	9,5
Fuel consumption at 50% load	lt/h	6,5
General data		
Rated capacity	Ah	1x100
Auxiliary voltage	V	12
		504

I/s

I/s

mm

Kg (+/-3%)

67

57,6

200x100x140

80

911





# Engine

	Cummins
	\$3.8G6
	Stage 0
	Mechanic
°C	50
Tipo	liquid (water + 50% Paraflu11)
Kwm	46,7
CV	63,5
Tipo	4 strokes
Tipo	Direct
Tipo	Turbo
N	4
	L
mm	97
mm	128
lt	3,782
	15W40-API CI-4/CH-4 ACEA E5-E7
%	<0,3% fuel consumption
lt .	11
lt .	11
	Tipo Kwm CV Tipo Tipo N mm mm It

# Alterna

### \* May vary based on stock availability. However, a primary brand will be used.

Factory		Stamford
Model		S1L2-R1
Prime power prp 3ph+n	KVA	50
Voltage regulator (voltage accuracy)	+/- %	1
Poles	N°	4
Phases	N°	3+N
Standard windings connection		Star Series Star Series
Stator/rotor impregnation		H (Outdoor Temp 40°C)
Efficiency	%	89,2
Engine coupling		Elastic disk
Short circuit current		>= 300% (3In)
Protection degree	IP	23
Cooling system		Self ventilating
Maxium overspeed	rpm	2250
Waveform distortion	%	<5
Exciter		Diode bridge

# Standard operating environmental conditions

Ambient temperature	°C	25
Relative humidity	%	30
Max altitude	mt	1000






GE.CU.055/050.BF+011

# **Control Systems on board QPE-C-VSC-BF**





operating scheme - schema di funzionamento

# **QPE** Automatic panel without switching on board

The QPE-C control panel represents the evolution of the panel for the control and management of the gen set. With its microprocessor logic it is able to meet any user requested features. The dual operation mode manual and automatic guarantees to every type of functionality protection, analysis and control of the generating set in order to make the management easy and efficient. Variant without transfer switch on board. ATS panel type QC as optional. The panel manages the QC panels directly or any other ATS panel.

# Mechanical features

Protection degree	IP	55
Totection degree	11	33

# Battery charger

Model		ELCOS - CB1
Maximum output current	Α	2,5
Output dc voltage (selectable)	Vdc	12-24
Input ac voltage (selectable)	Vac	220-260
Frequency	Hz	50-60

# Data Communication

Data connection port	RS-485
Communication protocol	Mod-bus RTU-8N1

# Remotable functions in terminal box

Gs start
Genset contactor close/open command
Common alarm - dc output
Gs start with key in off position (only in mrs mode)
Management of the automatic fuel refilling system

Gs lock
Mains contactor close/open command
Gs test without load
Programmable output - volt free output







# Control Module



#### **Specifics**

#### **Applications**

Emergency to the mains Stand-alone Construction site/rental Self-production

#### **ENGINE MEASURES**

Fuel tank level % Engine oil pressure bar (1)

Engine coolant temperature °c (1) Total run time

Partial run time

Hours to maintenance

Battery voltage

Battery charging voltage

Start-ups counter

Engine speed (2)

Engine oil temperature (2)

Cooler temperature (2) Engine oil level (2)

Engine coolant level (2)

Engine coolant pressure (2)

Turbo pressure (2)

Fuel consumption (2)

Tank autonomy - hrs (5)

Fuel remaining quatity (5)

Fuel used quantity (5)

#### **ALTERNATOR MEASURES**

Generator voltage I1, I2, I3 Generator voltage I1-n, I2-n, I3-n Generator frequency

Generator current 11, 12, 13

Generator apparent power kva

Generator active power kw

Generator reactive power kvar

Generator accumulated power kwh

Power factor cosfi

#### **MAINS MEASURES**

Mains voltage I1, I2, I3 Mains voltage I1-n, I2-n, I3-n

Mains frequency

### **COMMUNICATION PORTS**

Can-bus port

Rs485 port with mod-bus rtu communication Rs232 port for display connection

Usb port for parameters saving and firmware update

#### **EQUIPMENT**

Microprocessor logic Back-lit display

Programmable from display

16 event log

Multiple display languages

Stop button

Start button

Test button

Reset alarm button

Alarm mute button

Fuel transfer pump activation button

Glow-plug activation button

#### PRE-ALARMS/ ALARMS

Common alarm

Fuel reserve (pre-alarm)

Low fuel level (alarm)

Tank overflow

Charge alternator failed (dinamo)

Low oil pressure (pre-alarm) (1)

Low oil pressure (alarm)

Oil sensor failed (alarm)

High coolant temperature (pre-alarm) (1)

High coolant temperature (alarm)

Low coolant temperature (pre-alarm)

Low water level (1)

Water in fuel (1)

Battery undervoltage Battery overvoltage

Gs failure to start

Gs failure to stop

Can-bus failure

No can-bus communication

Genset overload I1, I2, I3 phases

Genset short circuit Genset overvoltage

Genset undervoltage Genset high frequency

Genset low frequency

Overspeed

Reverse power

Earth fault (pre-alarm)

Earth fault (alarm) Block from password

Can communication failed

Maintenance request

Emergency button pressed

Remote emergency active

Forced stop

External battery failed

Fuel theft

Genset negative phase sequence

Mains negative phase sequence

Fuel theft protection

### VISUALIZATIONS ON CONTROL

**ELCOS** 

MC4 AMF - MRS

#### MODULE/DISPLAY Pre-alarms

Alarms

**Brand** Model

Operating mode

Engine measures

Alternator measures

Mains measures

Date and time

Operating mode

Genset status Mains status

Mains contactor status

Genset contactor status

Digital input and output status

Grounding current ma (3)

Grounding current threshold ma (3)

Delay time of differential protection (3)

Glow plugs status

#### **CONTROL MODULE FUNCTIONS**

Automatic start and stop when the mains fails (7)

Remote start and stop

Remote start and stop with key in off position

Manual start and stop

Emergency stop button on panel board

Remote emergency stop

Remote lock

Remote test without load

Remote test on load

Scheduled start-ups

Modbus commands (start, stop, reset, test)

#### **CONTROL MODULE SPECIAL FUNCTIONS** (on demand)

Automatic charging of an external battery

Dummy load (4) Load shedding (4)

Redundant starter motor management

Fuel monitoring Gs battery load test

Idle mode

Service phone number indication

Variable speed generator

Master / slave mode



### **OPTIONAL**



Soundproofed container 55 dB(A) @ 7 mt and 60/62 dB(A) @ 1mt"

Air inlet/outlet sound attenuator for room

Exhaust

Exhaust flexible expansion joint External residential muffler Exhaust flexible pipe (fap) anti-particulate filter Exhaust catalyst (cat)

Fuel Supply

Bulk tank connections with 3 way valve Bulk tank connections Automatic fuel refilling system on board

Engine

Cyclone air filter

Redundant start-up battery kit

Engine pre-heater 230vsuper hot
Oil pressure and coolant temperature gauge (only with qpe or +14 variant)
Oil change pump
Engine liquids + 50°c, - 40°c (oil and antifreeze)
Electronic speed governor
Battery disconnector
Automatic refilling oil system
1000 working hours spare parts kit

Alternator

Avr pre-arranged for parallel Stator windings thermistors - pt100 - in the alternator box (not managed)

Anti-condensation heater

Panel & connection

Rcd with adjustable current and excludible Automatic transfer switch (qc) Utf energy meter with arcudi terminal Tamperproof panel ip55

MC4 optional

Telemonitoring with software
Remote panel
Rs485/usb converter
Rs485/lan converter
16 relais card (volt free output)
Gms modem - sms remote management
Radiocontrol
Gsm remote control system with web application without sim card
Gps tracking system

### **PRP**


Engines of this rating provide unlimited hours of usage in a variable load application. The average load factor should not exceed 70% of the engine's prime power rating with a maximum number of 500 operational hours at 100% prime power rating. An overload capability of 10% is available, however, is limited to a period of 1 in every 12 hours

#### **LTP**

Limited-time running power is defined as the maximum power available, under the agreed operating conditions, for which the generating set is capable of delivering for up to 500h of operation per year with the maintenance intervals. The overload is not allowed.




GE.CU.055/050.BF+011







GE.CU.055/050.BF+011



# Left VENTILATION OF THE ROOM

The windows area in the generating set room needs to be (recommended):

Aspiration: on request

Expulsion: on request

ATTENTION: for a correct ventilation, the expulsion air and the exaust gas needs to be conveyed in the open-air

IMPORTANT:

- 1) Form and dimension refer to the generating set on catalogue
- 2) Form and dimension are subject to change in order to update or improve the products
- 3) This document can not be copied or trasmitted without ELCOS S.r.l. approval